



GOVT. OF ASSAM
OFFICE OF THE DIRECTOR,
FIRE AND EMERGENCY SERVICES, ASSAM, GUWAHATI.



F O R M - (G)

Dated Guwahati the 05/04/21

To,
The Principal/ Head Master,
Icon English School, Kharghuli- 2 No.,
(Sapaidung Bonda), Guwahati-26,
Dist:- Kamrup (M), Assam.

RENEWAL OF NO OBJECTION CERTIFICATE OF INBUILT FIRE FIGHTING/ FIRE PREVENTION AND MEANS OF ESCAPE MEASURES IN THE ICON ENGLISH SCHOOL AT KHARGHULI- 2 NO., (SAPAIDUNG BONDA), GUWAHATI-26, DIST:- KAMRUP (M), ASSAM.

With reference to your completion report under No.

NIL

Dated 18.03.2021 I hereby certify that the building as per description below at
Dag No. 65 Patta No. 03 Mouza Beltola,
(Place- Kharghuli- 2 No, Guwahati-26) has been inspected in respect of implementation of Inbuilt Fire Fighting/ Fire Prevention/ means of escape measures and is declared fit in respect fire safety. The Fire & Emergency Services, Assam has No objection in its occupation /utilization for the purpose of SCHOOL subject to condition mentioned below.

DETAILS OF APPROVED OCCUPATION:-


GROUND FLOOR:-

1. Floor area:- 878.23 m²

2. Purpose of utilization:-
For School Purpose.

Details of inbuilt Fire Fighting and Fire Prevention measures:


1. Manually Operated Electric Fire Alarm system
2. Fire Extinguishers


S.P. cum F&ES Adviser,
for and on behalf of
Director of Fire and Emergency Services,
Assam, Guwahati.

Dated Guwahati the _____


NO. F&ES/FPW/
Copy to:-


1. The Deputy Commissioner, Kamrup (M), Assam for information and necessary action.
2. The Commissioner / Chairman, G.M.C. Guwahati, Assam for information and necessary action.
3. The Station Officer, Chandmari F&ES Station, for information.



S.P. cum F&ES Adviser,
for and on behalf of
Director of Fire and Emergency Services,
Assam, Guwahati.

CONDITION:-

1. The N.O.C. is valid up to: - 31.03.2022.
2. There should not be any change of Trade for which this License has been issued.
3. There should not be any structural change in the building either horizontally or vertically. There should not also be any change in the existing arrangements.
4. The Fire Fighting equipments should be in serviceable condition at all time.
5. Water reservoir should always be kept full up to brim.
6. The entrance and exit and the water reservoir should always be free from any obstruction/ projection.
7. The N.O.C. is liable to be cancelled if the premises (for which the N.O.C. is granted) when inspected are not found conforming to the description and condition under which this N.O.C. is granted.


PRINCIPAL
ICON ENGLISH SCHOOL
SAPAIDANG, GUWAHATI-26


S.P. cum F&ES Adviser,
for and on behalf of


SECRETARY, M. C.
ICON ENGLISH SCHOOL
SAPAIDANG, GUWAHATI-26